

CERTIFICATE

SKZ



SKZ - Testing GmbH awards the following company

**LK Pex AB
Rönnåsgatan 4 A
52321 ULRICEHAMN
SCHWEDEN**

Production site: LK Pex AB, SE-52321 ULRICEHAMN

the right to use the SKZ-mark



A 341

for the following plastic products

Heating pipes made of crosslinked polyethylene PE-Xa

Group 1 ($d_n \leq 63$ mm)

Group 2 (75 mm $\leq d_n \leq 160$ mm)

Application class 4 / design pressure 6 bar

Application class 5 / design pressure 6 bar

according to SKZ-Specification for Tests and Inspection HR 3.2:2015-04.

Users of the SKZ-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 1 February 2002

Date of expiry: 24 May 2027

Würzburg, 31 May 2023/



i.V.

A handwritten signature in blue ink, appearing to read 'Krause'.

**Dipl.-Ing. Hans-Peter Krause
Head of Certification Body**

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de
The Certification Body of SKZ - Testing GmbH is accredited by DAkkS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.